

Appendix A: City of West Haven Collection System Releases From 1/1/2012 to 12/15/2017

Date/Time of Event	Duration (hours)	Bypass Location	More Description of Location	Source of Notification	Weather	Cause of Bypass	Volume ¹ (gallons)	Reached Catch Basin?	Affected Surface Water ²	Steps Taken to Stop Overflow	Steps Taken to Prevent Future Overflows	Cleaning Method	Date Reported to DEEP	Date of Last Bypass at this Location ³
1/18/2012 12:30 PM	0.1	MH (16-158)	near 114 Boston Post Road	Homeowner/ Resident	Dry	Grease	10 – 50	No	N/A	Regular maintenance of sewer	Regular maintenance of main sewer	Vactor truck	1/18/2012	
1/22/2012 10:20 AM	1.5	MH (10-299B)	249 Sawmill Road	Other (City Engineering Dept.)		Grease	50 – 100	No		Regular maintenance of sewer	Regular maintenance of main sewer	Vactor truck		
2/7/2012 8:50 AM	1	MH (2-26)	Intersection of Winslow Dr. & Jones Hill Road	Homeowner/ Resident		Debris	50 – 100	No		Regular maintenance of sewer	Regular maintenance of main sewer	Vactor truck		
2/7/2012 7:51 PM	0.1	22 SECOND AVE	N/A	Homeowner/ Resident		Grease	< 10	No	Basement	Regular maintenance of sewer	Regular maintenance of main sewer	Vactor truck		
2/13/2012 12:25 PM	0.5	MH (13-265)	Campbell Ave. & Terrace Ave.	WPCC employee		Grease	50 – 100	No		Regular maintenance of sewer	Regular maintenance of sewer	Vactor truck		
2/19/2012 10:30 AM	1	MH (4-109)	Island Lane & Benham Hill Road	Other (sight)		Grease	10 – 50	No		Regular maintenance of sewer	Regular maintenance of main sewer			
2/21/2012 11:35 AM	0.5	MH (13-193)	28 Spring Street	Other (City Employee)		Grease	100 – 1,000	No		Regular maintenance of sewer	Regular maintenance of sewer	Vactor truck		
2/27/2012 9:10 AM	0.5	MH ()	Rockview St. & Boston Post Road, Catch basin on Daytona St.	Homeowner/ Resident		Grease	50 – 100	No		Regular maintenance of sewer		Vactor truck		
3/4/2012 9:45 AM	1.5	MH ()	143 Beatrice Drive	Homeowner/ Resident		Other (Not included in report)	100 – 1,000	No		Regular maintenance of sewer	Regular maintenance of main sewer			

1. Volumes discharged are visual estimates. Ranges include the larger value in the range (ex: 10-50 gal includes 50 gal, where 50-100 gal includes 100 gal).

2. Where the bypass reached storm basins or surface waters, the volume discharged to the receiving water is assumed to be the entire volume reported.

3. Period of record: July 5, 2006 – December 31, 2017. Blank entry indicates that no previous bypass event occurred at this location during this period of record.

Appendix A: City of West Haven Collection System Releases From 1/1/2012 to 12/15/2017

Date/Time of Event	Duration (hours)	Bypass Location	More Description of Location	Source of Notification	Weather	Cause of Bypass	Volume ¹ (gallons)	Reached Catch Basin?	Affected Surface Water ²	Steps Taken to Stop Overflow	Steps Taken to Prevent Future Overflows	Cleaning Method	Date Reported to DEEP	Date of Last Bypass at this Location ³
3/6/2012 7:40 AM	2.5	34 BAYSHORE DR	Not given in report, likely somewhere on bayshore drive senior housing authority property	Other (Housing Authority)		Grease	100 – 1,000	No	Basement	Regular maintenance of sewer	Regular maintenance of main sewer	Vactor truck		
3/6/2012 6:00 PM	0.5	Other:	16 S. Forest Circle	WPCCEmployee		Grease	50 – 100	No		Regular maintenance of sewer	Regular maintenance of sewer	Vactor truck		
3/7/2012 11:10 AM	0.1	MH (8-183)	Intersection of Thomas St @ Morse Ave	Other (Highway Dept.)		Grease	50 – 100	No		Regular maintenance of sewer	Regular maintenance of sewer	Vactor truck		
4/2/2012 5:00 PM	0	Outfall Pipe	Outflow pipe behind treatment plant (2 Beach Street)	WPCCEmployee		Collapsed Pipe	Unknown	No		Other: Fixed broken pipe				
4/2/2012 5:30 PM	0.5	116 DALTON ST	116 Dalton Street, report not clear on type of location	Homeowner/Resident		Grease	100 – 1,000	No	Basement			Tom Hill Septic/Septage hauler		
4/6/2012 1:00 PM	0.5	MH (2-27)	Jones Hill Road & Winslow Drive	Other (Bill Norton)		Grease	10 – 50	No		Regular maintenance of sewer	Regular maintenance of sewer	Vactor truck		
4/10/2012 6:30 PM	1	Other:	260 Benham Hill Road/Ora Mason Library	Homeowner/Resident		Grease	10 – 50	No		Regular maintenance of sewer	Regular maintenance of main sewer	West Haven personnel cleaned area		
4/21/2012 9:15 AM	0.5	MH (9-117)	376 Spring St. & Kenneth Street	Homeowner/Resident		Grease	100 – 1,000	No		Regular maintenance of sewer	Regular maintenance of main sewer	Vactor truck		
5/21/2012 1:00 AM	1.5	MH (16-137)	Route 1 & Brower Street	Police Department		Grease	50 – 100	No		Regular maintenance of sewer	Regular maintenance of main sewer			
6/17/2012 6:30 PM	1.5	MH ()	450 Painter Drive - Core River Pump Station	WPCCEmployee		Mechanical Equipment Failure	100 – 1,000	No				Vactor truck		

1. Volumes discharged are visual estimates. Ranges include the larger value in the range (ex: 10-50 gal includes 50 gal, where 50-100 gal includes 100 gal).
2. Where the bypass reached storm basins or surface waters, the volume discharged to the receiving water is assumed to be the entire volume reported.
3. Period of record: July 5, 2006 – December 31, 2017. Blank entry indicates that no previous bypass event occurred at this location during this period of record.

Appendix A: City of West Haven Collection System Releases From 1/1/2012 to 12/15/2017

Date/Time of Event	Duration (hours)	Bypass Location	More Description of Location	Source of Notification	Weather	Cause of Bypass	Volume ¹ (gallons)	Reached Catch Basin?	Affected Surface Water ²	Steps Taken to Stop Overflow	Steps Taken to Prevent Future Overflows	Cleaning Method	Date Reported to DEEP	Date of Last Bypass at this Location ³
6/21/2012 8:50 AM	0.5	MH ()	N/A	Homeowner/ Resident		Grease	50 – 100	No	Basement	Regular maintenance of sewer	Regular maintenance of main sewer	Vactor truck		
6/26/2012 9:05 AM	0.5	MH (8-182)	Beach St. & Morse Avenue	Other (Highway Dept.)		Grease	50 – 100	No		Regular maintenance of sewer	Regular maintenance of sewer	Vactor truck		
7/16/2012 2:00 PM	0.5	MH (9-84)	32 Eileen Road	Homeowner/ Resident		Grease	50 – 100	No		Regular maintenance of sewer	Regular maintenance of sewer	Vactor truck		
8/10/2012 5:21 PM	1	Cove River Pump Station	350 Painter Drive	Police Department		Electrical Equipment Failure	1,000 – 25,000	No		Other: Repair equipment		N/A		
8/13/2012 10:30 AM	0.5	Main Pump Station	165 Blohm Street	WPCC employee		Mechanical Equipment Failure	1,000 – 25,000	No		Other: Fixed				
8/28/2012 2:35 PM	1	19 BEACH ST	N/A	Homeowner/ Resident		Grease	10 – 50	No	Basement	Regular maintenance of sewer	Regular maintenance of main sewer	Tom Hill Septic/Septage hauler		
9/15/2012 2:50 PM	1	MH (13-193)	24 Spring Street	Police Department		Grease	10 – 50	No		Regular maintenance of sewer	Regular maintenance of sewer	Vactor truck		
9/17/2012 7:15 AM	0.1	MH (13-226)	Intersection of West Spring St. & Cambell Avenue	Homeowner/ Resident		Grease	10 – 50	No		Regular maintenance of sewer	Regular maintenance of main sewer	Vactor truck		
9/28/2012 2:46 PM	0.5	MH (7-230)	N/A	Homeowner/ Resident		Grease	10 – 50	No	Basement	Regular maintenance of sewer	Regular maintenance of main sewer	Vactor truck		
9/28/2012 3:55 PM	0.5	MH (7-224)	50 Chestnut Street	Homeowner/ Resident		Grease	100 – 1,000	No		Regular maintenance of sewer	Regular maintenance of main sewer	Vactor truck		
10/3/2012 12:00 PM	25	Oyster River Pump Station	171 Beatrice Drive	WPCC employee		Other (Broken Force Main)	Unknown	No		Other: Line fixed 20" force main replaced clamp				

1. Volumes discharged are visual estimates. Ranges include the larger value in the range (ex: 10-50 gal includes 50 gal, where 50-100 gal includes 100 gal).

2. Where the bypass reached storm basins or surface waters, the volume discharged to the receiving water is assumed to be the entire volume reported.

3. Period of record: July 5, 2006 – December 31, 2017. Blank entry indicates that no previous bypass event occurred at this location during this period of record.

Appendix A: City of West Haven Collection System Releases From 1/1/2012 to 12/15/2017

Date/Time of Event	Duration (hours)	Bypass Location	More Description of Location	Source of Notification	Weather	Cause of Bypass	Volume ¹ (gallons)	Reached Catch Basin?	Affected Surface Water ²	Steps Taken to Stop Overflow	Steps Taken to Prevent Future Overflows	Cleaning Method	Date Reported to DEEP	Date of Last Bypass at this Location ³
10/15/2012 7:30 AM	0.5	MH (5-142)	82 Cherry Lane	Homeowner/ Resident		Grease	50 – 100	No		Regular maintenance of sewer	Regular maintenance of main sewer	Vactor truck		
10/15/2012 12:00 PM	1	Main Pump Station	165 Blohm Street	WPCC employee		Mechanical Equipment Failure	100 – 1,000	No		Other: Shut down water	Other: Upgrade equipment	Tom Hill Septic/Septage hauler		
10/15/2012 8:00 PM	0	MH ()	#5 & #6 Great Street	Police Department		Unknown	10 – 50	No				Vactor truck		
10/16/2012 10:00 AM	0.5	Main Pump Station	165 Blohm Street	WPCC employee		Mechanical Equipment Failure	100 – 1,000	No		Other: Shut down unit for repairs to PLC for controls and talk to manufacturer	Other: Speaking with manufacturer	Tom Hill Septic/Septage hauler		
10/29/2012 5:30 PM	0	Dawson Avenue Pump Station	1 Dawson Avenue	Other (Fire Department)		Grease	> 100,000	No		Other: Repair starter generator	Other: Keep generator in operating condition	West Haven personnel cleaned area		
10/30/2012 1:40 PM	0.5	MH (1-50)	MH at the end of Templeton Street	Other (City Engineer)		Electrical Equipment Failure	10 – 50	No		Other: Pumps at Trubull Street Pump station re-set	Other: Pumping sequence was monitored and corrected	West Haven personnel cleaned area		
11/21/2012 6:00 PM	0.5	MH (13-47)	82 Miami Street	Homeowner/ Resident		Grease	50 – 100	No		Regular maintenance of sewer	Regular maintenance of main sewer	Vactor truck		
12/15/2012 4:45 PM	0.5	MH (9-182)	430 Sawmill Road	Police Department		Unknown	10 – 50	No		Regular maintenance of sewer	Regular maintenance of main sewer	West Haven personnel cleaned area		
12/21/2012 11:48 AM	0.5	71 PARKER AVE	N/A	Homeowner/ Resident		Grease	10 – 50	No	Basement	Regular maintenance of sewer	Regular maintenance of main sewer	N/A		8/17/2010
1/14/2013 10:30 AM	1	MH (4-109)	Benham Hill Road	WPCC employee	Dry	Debris	10 – 50	Yes	Oyster River	Regular maintenance of sewer	Regular maintenance of main sewer	Tom Hill Septic/Septage hauler	1/14/2013	2/19/2012

1. Volumes discharged are visual estimates. Ranges include the larger value in the range (ex: 10-50 gal includes 50 gal, where 50-100 gal includes 100 gal).

2. Where the bypass reached storm basins or surface waters, the volume discharged to the receiving water is assumed to be the entire volume reported.

3. Period of record: July 5, 2006 – December 31, 2017. Blank entry indicates that no previous bypass event occurred at this location during this period of record.

Appendix A: City of West Haven Collection System Releases From 1/1/2012 to 12/15/2017

Date/Time of Event	Duration (hours)	Bypass Location	More Description of Location	Source of Notification	Weather	Cause of Bypass	Volume ¹ (gallons)	Reached Catch Basin?	Affected Surface Water ²	Steps Taken to Stop Overflow	Steps Taken to Prevent Future Overflows	Cleaning Method	Date Reported to DEEP	Date of Last Bypass at this Location ³
2/25/2013 8:30 AM	1.5	MH (6-107)	Morrissey Pump Station	Other (Housing Authority employee)	Dry	Electrical Equipment Failure	10 – 50	Yes	Long Island Sound	Other: Alarm issue	Other: New float added to alarm	West Haven personnel cleaned area	2/25/2013	
2/27/2013 9:15 AM	13	MH (5-86)	Ocean Avenue near Platt Avenue	Homeowner/ Resident	Wet	Heavy Rain	75,000 - 100,000	Yes	Long Island Sound	Other: Looking into flow survey for action of bypasses	Regular maintenance of main sewer	Tom Hill Septic/Septage hauler	2/27/2013	8/28/2011
3/2/2013 2:45 PM	70	122 HILLTOP LA	122 Hill Top Lane - private lateral	Police Department	Dry	Grease	1,000 – 25,000	No	Basement	Regular maintenance of sewer	Regular maintenance of main sewer	Vactor truck	3/2/2013	
3/5/2013 4:30 PM	0.5	MH (8-24)	near 100 Campbell Avenue	WPCC employee	Dry	Grease	10 – 50	Unknown	N/A	Regular maintenance of sewer	Regular maintenance of main sewer	Vactor truck	3/5/2013	11/24/2007
3/22/2013 4:38 PM	1.5	MH (13-193)	Lambert Street @ Spring Street	Homeowner/ Resident	Dry	Grease	10 – 50	No	N/A	Regular maintenance of sewer	Regular maintenance of sewer	Vactor truck	3/22/2013	9/15/2012
3/26/2013 8:45 AM	0.1	Main Pump Station	165 BLOHM ST	WPCC employee	Dry	Mechanical Equipment Failure	< 10	Yes	Old Field Creek	Other: Stopped heavy cleaning of lines leading to station	Other: Stopped cleaning lines in the area	West Haven personnel cleaned area	3/26/2013	10/16/2012
3/30/2013 3:30 PM	0.5	MH (13-166)	Private MH at 34 Homestead Avenue	Homeowner/ Resident	Dry	Grease	10 – 50	No	N/A	Regular maintenance of sewer	Regular maintenance of main sewer	West Haven personnel cleaned area	3/30/2013	10/26/2012
4/7/2013 7:45 PM	1	MH (5-29A)	near 109 Roosevelt Avenue	Homeowner/ Resident	Dry	Debris	50 – 100	No	N/A	Regular maintenance of sewer	Regular maintenance of sewer	Vactor truck	4/7/2013	
5/1/2013 4:30 PM	1	MH (2-161)	near 131 - 133 Beatrice Drive	Homeowner/ Resident	Dry	Grease	10 – 50	Unknown	N/A	Regular maintenance of sewer	Regular maintenance of main sewer	Vactor truck	5/1/2013	4/4/2011
5/6/2013 11:30 AM	2	MH (4-52)	near 475 Heffernan Drive	Other (Employee of Business GHP)	Dry	Unknown	1,000 – 25,000	Yes	Oyster River	Regular maintenance of sewer	Regular maintenance of main sewer	Tom Hill Septic/Septage hauler	5/6/2013	

1. Volumes discharged are visual estimates. Ranges include the larger value in the range (ex: 10-50 gal includes 50 gal, where 50-100 gal includes 100 gal).

2. Where the bypass reached storm basins or surface waters, the volume discharged to the receiving water is assumed to be the entire volume reported.

3. Period of record: July 5, 2006 – December 31, 2017. Blank entry indicates that no previous bypass event occurred at this location during this period of record.

Appendix A: City of West Haven Collection System Releases From 1/1/2012 to 12/15/2017

Date/Time of Event	Duration (hours)	Bypass Location	More Description of Location	Source of Notification	Weather	Cause of Bypass	Volume ¹ (gallons)	Reached Catch Basin?	Affected Surface Water ²	Steps Taken to Stop Overflow	Steps Taken to Prevent Future Overflows	Cleaning Method	Date Reported to DEEP	Date of Last Bypass at this Location ³
6/7/2013 8:00 PM	22.5	MH (5-40)	Ocean Ave @ Fairview	WPCC employee	Wet	Heavy Rain	1,000 – 25,000	Yes	Long Island Sound	Other: Looking into drainage area as part of our CMOM order	Regular maintenance of main sewer	West Haven personnel cleaned area	6/7/2013	12/12/2008
6/7/2013 8:30 PM	12	MH (5-95)	Platt Avenue & Maple Street	Police Department	Wet	Heavy Rain	1,000 – 25,000	Yes	Long Island Sound	Other: Checking pump station	Other: Check pump station	West Haven personnel cleaned area	6/8/2013	12/12/2008
6/7/2013 11:45 PM	15	MH (8-100)	Blohm Street	Homeowner/Resident	Wet	Heavy Rain	> 100,000	Yes	Long Island Sound	Other: Looking into sanitary sewer system as part of our CMOM order	Regular maintenance of main sewer	Tom Hill Septic/Septage hauler	6/7/2013	3/26/2013
6/8/2013 8:18 AM	0.5	MH (1-50)	1 Templeton Street	Homeowner/Resident	Wet	Heavy Rain	100 – 1,000	Yes	Long Island Sound	Other: Operated at pump station until level reached appropriate levels	Other: Check pump station	West Haven personnel cleaned area	6/8/2013	10/30/2012
6/8/2013 9:00 AM	1	54 MORRIS ST	N/A	Homeowner/Resident	Wet	Heavy Rain	1,000 – 25,000	No	Basement	Regular maintenance of sewer	Regular maintenance of main sewer	Tom Hill Septic/Septage hauler	6/8/2013	1/14/2011
6/13/2013 11:15 AM	2	MH (7-132)	Painter Drive	WPCC employee	Wet	Mechanical Equipment Failure	10 – 50	Yes	Cove River	Other: Getting pump station back on line	Other: Repair Pump Station	West Haven personnel cleaned area	6/13/2013	6/17/2012
6/20/2013 7:55 AM	0.5	MH (10-309)	West Spring Street @ Greta Street	Other (Highway crew)	Dry	Grease	50 – 100	Yes	Cove River	Regular maintenance of sewer	Regular maintenance of main sewer	N/A	6/20/2013	12/20/2013
6/25/2013 10:20 AM	1	71 RICHARDS ST	N/A	Homeowner/Resident	Dry	Grease	10 – 50	No	Basement	Regular maintenance of sewer	Regular maintenance of main sewer	Service Master/Other contractor	6/25/2013	12/10/2006
7/6/2013 12:15 PM	0.5	Main Pump Station	165 BLOHM ST	WPCC employee	Dry	Mechanical Equipment Failure	100 – 1,000	Yes	New Haven Harbor	Other: Turned pumps on at low speed	Other: Reset all pumps	Tom Hill Septic/Septage hauler	7/6/2013	6/7/2013

1. Volumes discharged are visual estimates. Ranges include the larger value in the range (ex: 10-50 gal includes 50 gal, where 50-100 gal includes 100 gal).

2. Where the bypass reached storm basins or surface waters, the volume discharged to the receiving water is assumed to be the entire volume reported.

3. Period of record: July 5, 2006 – December 31, 2017. Blank entry indicates that no previous bypass event occurred at this location during this period of record.

Appendix A: City of West Haven Collection System Releases From 1/1/2012 to 12/15/2017

Date/Time of Event	Duration (hours)	Bypass Location	More Description of Location	Source of Notification	Weather	Cause of Bypass	Volume ¹ (gallons)	Reached Catch Basin?	Affected Surface Water ²	Steps Taken to Stop Overflow	Steps Taken to Prevent Future Overflows	Cleaning Method	Date Reported to DEEP	Date of Last Bypass at this Location ³
7/15/2013 7:15 AM	0.5	MH (6-107)	MH bubbling in front of Morrissey Pump Station	Homeowner/Resident	Dry	Other (Float Stuck)	< 10	Yes	Cove River	Other: Cleared floats and cleaned wet well	Other: Cleared floats and cleaned wet well	West Haven personnel cleaned area	7/15/2013	2/25/2013
7/31/2013 2:00 PM	0.1	Main Pump Station	165 BLOHM ST	WPCC employee	Dry	Mechanical Equipment Failure	50 – 100	Yes	New Haven Harbor	Other: Cleared blockage in muffin monster unit	Other: Cleared blockage and monitoring unit	Tom Hill Septic/Septage hauler	7/31/2013	7/6/2013
8/4/2013 9:17 PM	1	Main Sewer	589 Third Avenue	Homeowner/Resident	Dry	Grease	50 – 100	Unknown	N/A	Regular maintenance of sewer	Regular maintenance of sewer	Service Master/Other contractor	8/4/2013	
8/6/2013 1:45 PM	0.5	MH (13-66)	near 57 Sanford Street	Homeowner/Resident	Dry	Grease	10 – 50	Yes	Cove River	Regular maintenance of sewer	Regular maintenance of main sewer	West Haven personnel cleaned area	8/6/2013	12/16/2007
9/25/2013 6:40 AM	2.5	MH (4-52)	near 475 Heffernan Drive	WPCC employee	Dry	Grease	100 – 1,000	Yes	Oyster River	Regular maintenance of sewer	Other: Use root cleaning company to clean roots and clean line	Tom Hill Septic/Septage hauler	9/25/2013	5/6/2013
10/18/2013 2:05 PM	1	MH (13-210)	near 63, 66, 67 Clifton street	Homeowner/Resident	Dry	Grease	10 – 50	No	N/A	Regular maintenance of sewer	Regular maintenance of sewer	Service Master/Other contractor	10/18/2013	6/10/2010
10/31/2013 10:20 AM	1	MH (2-181)	near 16 Ida Lane	Police Department	Dry	Grease	10 – 50	Yes	Oyster River	Other: Relieved blockage as soon as possible	Regular maintenance of main sewer	West Haven personnel cleaned area	10/31/2013	5/27/2011
11/2/2013 3:30 PM	1	MH (9-84)	near 32 Eileen Road	Homeowner/Resident	Dry	Grease	10 – 50	No	N/A	Regular maintenance of sewer	Regular maintenance of sewer	Vactor truck	11/2/2013	7/16/2012
11/14/2013 7:00 PM	1.5	MH (5-134)	near 124 Bluff Avenue	Homeowner/Resident	Dry	Grease	10 – 50	No	N/A	Regular maintenance of sewer	Regular maintenance of sewer	Vactor truck	11/14/2013	4/15/2011
11/16/2013 9:10 AM	0.5	MH (5-133)	near 119 Bluff Avenue	Homeowner/Resident	Dry	Grease	50 – 100	Yes	Cove River	Regular maintenance of sewer	Regular maintenance of main sewer	West Haven personnel cleaned area	11/16/2013	4/17/2011

1. Volumes discharged are visual estimates. Ranges include the larger value in the range (ex: 10-50 gal includes 50 gal, where 50-100 gal includes 100 gal).

2. Where the bypass reached storm basins or surface waters, the volume discharged to the receiving water is assumed to be the entire volume reported.

3. Period of record: July 5, 2006 – December 31, 2017. Blank entry indicates that no previous bypass event occurred at this location during this period of record.

Appendix A: City of West Haven Collection System Releases From 1/1/2012 to 12/15/2017

Date/Time of Event	Duration (hours)	Bypass Location	More Description of Location	Source of Notification	Weather	Cause of Bypass	Volume ¹ (gallons)	Reached Catch Basin?	Affected Surface Water ²	Steps Taken to Stop Overflow	Steps Taken to Prevent Future Overflows	Cleaning Method	Date Reported to DEEP	Date of Last Bypass at this Location ³
12/5/2013 11:30 AM	1	MH (9-125)	cross country between Cynthia Circle & Meloy Road in woods	Homeowner/ Resident	Dry	Grease	Unknown	Yes	Cove River	Regular maintenance of sewer	Regular maintenance of main sewer	N/A	12/5/2013	
12/8/2013 8:00 AM	0.5	Main Pump Station	165 BLOHM ST	WPCC employee	Dry	Mechanical Equipment Failure	50 – 100	Yes	New Haven Harbor	Regular maintenance of sewer	Other: Increased inspection of outlet drain on equipment	N/A	12/8/2013	7/31/2013
12/20/2013 1:40 PM	0.1	MH (10-309)	near 317 West Spring Street, Westbrook Apartments	Homeowner/ Resident	Dry	Grease	10 – 50	Yes	Cove River	Regular maintenance of sewer	Other: Spoke to owners of apartment complex about not letting tenants dispose of grease down drains	N/A	12/20/2013	1/9/2011
12/24/2013 10:45 AM	0.1	Main Pump Station	Under door, 165 BLOHM ST	WPCC employee	Dry	Mechanical Equipment Failure	< 10	Yes	New Haven Harbor	Other: Cleared jammed equipment & put redundant equipment on line	Other: Alarm will be installed	West Haven personnel cleaned area	12/24/2013	12/8/2013
12/26/2013 8:15 AM	0.1	MH (2-181)	near 16 Ida Lane	Homeowner/ Resident	Dry	Grease	1,000 – 25,000	Yes	Oyster River	Regular maintenance of sewer	Regular maintenance of main sewer	West Haven personnel cleaned area	12/26/2013	10/31/2013
12/26/2013 8:20 PM	1.5	MH (2-70)	near 15 Woodvale Road	Homeowner/ Resident	Dry	Grease	50 – 100	No	N/A	Regular maintenance of sewer	Regular maintenance of main sewer	Vactor truck	12/27/2013	11/18/2010
12/27/2013 10:35 AM	1.5	MH (13-194)	dead end of Lambert St in woods	Homeowner/ Resident	Dry	Grease	100 – 1,000	Yes	New Haven Harbor	Regular maintenance of sewer	Regular maintenance of main sewer	West Haven personnel cleaned area	12/27/2013	2/7/2008
1/9/2014 4:48 PM	1	MH (7-133)	Painter Drive	WPCC employee	Dry	Mechanical Equipment Failure	< 10	Yes	Cove River	Other: Fixed problems with pumps at Cove River Pump Station	Other: Fixed problems with pumps at Cove River Pump Station	Vactor truck	1/9/2014	6/23/2011
1/10/2014 9:00 AM	0.25	MH (7-133)	Painter Dr MH, Simos Dr MH, Cove River Pump Station	WPCC employee	Dry	Mechanical Equipment Failure	1,000 – 25,000	Yes	Cove River	Other: Stopped bypass pumps and went back on pump station	Other: Two new pumps in place, waiting for seals and start up	West Haven personnel cleaned area	1/10/2014	1/9/2014

1. Volumes discharged are visual estimates. Ranges include the larger value in the range (ex: 10-50 gal includes 50 gal, where 50-100 gal includes 100 gal).

2. Where the bypass reached storm basins or surface waters, the volume discharged to the receiving water is assumed to be the entire volume reported.

3. Period of record: July 5, 2006 – December 31, 2017. Blank entry indicates that no previous bypass event occurred at this location during this period of record.

Appendix A: City of West Haven Collection System Releases From 1/1/2012 to 12/15/2017

Date/Time of Event	Duration (hours)	Bypass Location	More Description of Location	Source of Notification	Weather	Cause of Bypass	Volume ¹ (gallons)	Reached Catch Basin?	Affected Surface Water ²	Steps Taken to Stop Overflow	Steps Taken to Prevent Future Overflows	Cleaning Method	Date Reported to DEEP	Date of Last Bypass at this Location ³
1/12/2014 1:10 PM	1.25	MH (9-175)	near 90 Tuthill Street	Homeowner/ Resident	Dry	Grease	50 – 100	No	N/A	Regular maintenance of sewer	Regular maintenance of main sewer	Vactor truck	1/12/2014	
1/24/2014 10:40 PM	0.1	MH (5-142)	near 82 Cherry Lane	WPCC employee	Dry	Grease	10 – 50	No	N/A	Regular maintenance of sewer	Regular maintenance of main sewer	West Haven personnel cleaned area	1/24/2014	10/15/2012
2/10/2014 5:15 PM	0.5	MH (2-180)	near 28 Ida Lane	Other (West Haven Public Works)	Dry	Grease	10 – 50	No	N/A	Regular maintenance of sewer	Regular maintenance of main sewer	Vactor truck	2/10/2014	
2/23/2014 1:30 PM	0.25	MH (8-194)	Blohm Street and Morse Avenue	WPCC employee	Dry	Electric Utility Failure	50 – 100	Yes	Long Island Sound	Other: Reset pumps	Other: Checking on power	West Haven personnel cleaned area	2/23/2014	12/19/2008
2/23/2014 7:00 PM	4	MH (5-213)	Dyke Street and Captain Thomas Blvd	Homeowner/ Resident	Dry	Collapsed Pipe	100 – 1,000	Yes	Long Island Sound	Other: Fixed pipe	Other: Fix pipe	West Haven personnel cleaned area	2/23/2014	
2/25/2014 8:39 AM	0.1	MH (8-183)	bubbling up through pavement near 42 Morse Street	Other (Regional Water Authority)	Dry	Grease	10 – 50	Yes	Long Island Sound	Regular maintenance of sewer	Regular maintenance of main sewer	West Haven personnel cleaned area	2/25/2014	
3/3/2014 1:20 PM	0.25	MH (12-74)	near 52 Medford Street	Other (West Haven Public Works)	Dry	Grease	10 – 50	Yes	Cove River	Regular maintenance of sewer	Regular maintenance of main sewer	West Haven personnel cleaned area	3/3/2014	
3/16/2014 8:30 AM	0.1	Main Pump Station	165 BLOHM ST	WPCC employee	Dry	Mechanical Equipment Failure	10 – 50	No	N/A	Other: Flow from equipment stopped	Other: Cleared machine	West Haven personnel cleaned area	3/16/2014	12/24/2013
3/18/2014 6:00 PM	0.75	MH (13-101)	near 18 Tile Street	Homeowner/ Resident	Dry	Debris	50 – 100	Yes	Long Island Sound	Regular maintenance of sewer	Regular maintenance of main sewer	West Haven personnel cleaned area	3/18/2014	3/2/2007
3/30/2014 11:30 AM	1	MH (5-91)	near 30 Platt Avenue	WPCC employee	Wet	Capacity Limitations	100 – 1,000	Yes	Cove River	Other: Checking Dawson Avenue Pump Station	Other: Checking all pumps	West Haven personnel cleaned area	3/30/2014	

1. Volumes discharged are visual estimates. Ranges include the larger value in the range (ex: 10-50 gal includes 50 gal, where 50-100 gal includes 100 gal).

2. Where the bypass reached storm basins or surface waters, the volume discharged to the receiving water is assumed to be the entire volume reported.

3. Period of record: July 5, 2006 – December 31, 2017. Blank entry indicates that no previous bypass event occurred at this location during this period of record.

Appendix A: City of West Haven Collection System Releases From 1/1/2012 to 12/15/2017

Date/Time of Event	Duration (hours)	Bypass Location	More Description of Location	Source of Notification	Weather	Cause of Bypass	Volume ¹ (gallons)	Reached Catch Basin?	Affected Surface Water ²	Steps Taken to Stop Overflow	Steps Taken to Prevent Future Overflows	Cleaning Method	Date Reported to DEEP	Date of Last Bypass at this Location ³
3/30/2014 10:30 PM	1	MH (5-91)	near 30 Platt Avenue	WPCC employee	Wet	Mechanical Equipment Failure	100 – 1,000	No	N/A	Other: Repair problem at Dawson Avenue Pump Station, used temporary pump	Other: Repair pumps	West Haven personnel cleaned area	3/30/2014	3/30/2014
4/1/2014 7:00 PM	0.25	MH (13-166)	near 34 Homestead Avenue	WPCC employee	Dry	Grease	50 – 100	No	N/A	Regular maintenance of sewer	Regular maintenance of main sewer	Vactor truck	4/1/2014	3/30/2013
4/6/2014 12:30 PM	1	559 JONES HILL RD	N/A	Homeowner/ Resident	Dry	Grease	1,000 – 25,000	No	N/A	Regular maintenance of sewer	Regular maintenance of main sewer	Service Master/Other contractor	4/6/2014	
4/22/2014 11:15 AM	2.25	Front Avenue Pump Station	165 FRONT AVE	WPCC employee	Dry	Other (Leak in hose connection and bypass pumps)	100 – 1,000	Yes	Club Creek	Other: Stopped bypass pumping and went back to pump station	Other: Stopped bypass pumping and went back to pump station	Tom Hill Septic/Septage hauler	4/22/2014	4/8/2009
5/1/2014 1:30 AM	6	MH (1-5)	Beatrice Drive, Ocean Avenue, Platt Avenue, First Avenue, Blohm Street, Miami Street	WPCC employee	Wet	Electrical Equipment Failure	100 – 1,000	Yes	Long Island Sound	Other: Pumping as much water as possible	N/A	West Haven personnel cleaned area	5/1/2014	6/21/2012
5/1/2014 1:30 AM	1	MH (6-93)	near 630 Sawmill Road Extension	Homeowner/ Resident	Wet	Grease	100 – 1,000	No	N/A	Regular maintenance of sewer	Regular maintenance of main sewer	Vactor truck	5/1/2014	2/3/2010
5/1/2014 3:00 AM	2	Oyster River Pump Station	171 BEATRICE DR	WPCC employee	Wet	Electrical Equipment Failure	100 – 1,000	No	N/A	Other: Electrician on-site	Other: Electrician on-site	West Haven personnel cleaned area	5/1/2014	10/3/2012
5/1/2014 3:15 PM	1	MH (1-50)	near 1 Templeton Street	Homeowner/ Resident	Wet	Debris	100 – 1,000	Yes	Long Island Sound	Regular maintenance of sewer	Regular maintenance of main sewer	West Haven personnel cleaned area	5/1/2014	6/8/2013
5/6/2014 12:50 PM	0.25	134 JONES HILL RD	N/A	Homeowner/ Resident	Dry	Grease	50 – 100	Yes	Long Island Sound	Regular maintenance of sewer	Regular maintenance of main sewer	West Haven personnel cleaned area	5/6/2014	

1. Volumes discharged are visual estimates. Ranges include the larger value in the range (ex: 10-50 gal includes 50 gal, where 50-100 gal includes 100 gal).
2. Where the bypass reached storm basins or surface waters, the volume discharged to the receiving water is assumed to be the entire volume reported.
3. Period of record: July 5, 2006 – December 31, 2017. Blank entry indicates that no previous bypass event occurred at this location during this period of record.

Appendix A: City of West Haven Collection System Releases From 1/1/2012 to 12/15/2017

Date/Time of Event	Duration (hours)	Bypass Location	More Description of Location	Source of Notification	Weather	Cause of Bypass	Volume ¹ (gallons)	Reached Catch Basin?	Affected Surface Water ²	Steps Taken to Stop Overflow	Steps Taken to Prevent Future Overflows	Cleaning Method	Date Reported to DEEP	Date of Last Bypass at this Location ³
6/10/2014 1:30 PM	1	MH (10-130)	across from 611 Campbell Avenue	Other (Construction Worker)	Dry	Collapsed Pipe	100 – 1,000	Yes	Cove River	Other: Repair broken line	Other: Repair broken line	N/A	6/10/2014	
6/12/2014 4:00 PM	1.75	MH (13-47)	near 82 Miami Street and Lattanzi Street	Homeowner/ Resident	Dry	Grease	1,000 – 25,000	Yes	Cove River	Regular maintenance of sewer	Regular maintenance of main sewer	Tom Hill Septic/Septage hauler	6/12/2014	
7/31/2014 1:28 PM	0.25	MH (12-92)	in front of 27 Orford Street	Other (Called in by ERS 911 manhole bubbling over)	Dry	Debris	10 – 50	Yes	Cove River	Regular maintenance of sewer	Regular maintenance of main sewer	West Haven personnel cleaned area	7/31/2014	
8/17/2014 2:15 PM	1	MH (13-185)	Spring Street, near New Haven line	WPCC employee	Dry	Grease	10 – 50	No	N/A	Regular maintenance of sewer	Regular maintenance of main sewer	Vactor truck	8/17/2014	
8/22/2014 10:30 AM	0.5	MH (2-82)	Winslow Drive & Ruby Road	WPCC employee	Dry	Debris	10 – 50	No	N/A	Regular maintenance of sewer	Regular maintenance of main sewer	N/A	8/22/2014	
8/29/2014 10:14 AM	0.25	MH (2-181)	near 16 Ida Lane	Homeowner/ Resident	Dry	Unknown	10 – 50	Yes	Oyster River	Regular maintenance of sewer	Regular maintenance of main sewer	N/A	8/29/2014	12/26/2013
9/8/2014 10:30 AM	11.25	Savin Avenue Pump Station	423 CAPT THOMAS BLVD	WPCC employee	Dry	Mechanical Equipment Failure	100 – 1,000	No	N/A	Other: repair force main	Other: Inspect force main	Tom Hill Septic/Septage hauler	9/8/2014	
9/8/2014 11:15 AM	0.25	MH (13-265)	Campell Avenue & Terrace Avenue	Homeowner/ Resident	Dry	Grease	10 – 50	No	N/A	Regular maintenance of sewer	Regular maintenance of main sewer	Vactor truck	9/8/2014	7/22/2011
11/4/2014 11:20 AM	0.1	MH (10-229)	Intersection of Campbell Avenue and Highland Street	Other (Called in by ERS)	Dry	Debris	100 – 1,000	Yes	Unknown Name	Regular maintenance of sewer	Regular maintenance of main sewer	West Haven personnel cleaned area	11/4/2014	
11/5/2014 2:50 PM	0.25	414 UNION AVE	N/A	Homeowner/ Resident	Dry	Unknown	10 – 50	No	N/A	Regular maintenance of sewer	Regular maintenance of main sewer	West Haven personnel cleaned area	11/5/2014	

1. Volumes discharged are visual estimates. Ranges include the larger value in the range (ex: 10-50 gal includes 50 gal, where 50-100 gal includes 100 gal).

2. Where the bypass reached storm basins or surface waters, the volume discharged to the receiving water is assumed to be the entire volume reported.

3. Period of record: July 5, 2006 – December 31, 2017. Blank entry indicates that no previous bypass event occurred at this location during this period of record.

Appendix A: City of West Haven Collection System Releases From 1/1/2012 to 12/15/2017

Date/Time of Event	Duration (hours)	Bypass Location	More Description of Location	Source of Notification	Weather	Cause of Bypass	Volume ¹ (gallons)	Reached Catch Basin?	Affected Surface Water ²	Steps Taken to Stop Overflow	Steps Taken to Prevent Future Overflows	Cleaning Method	Date Reported to DEEP	Date of Last Bypass at this Location ³
11/13/2014 7:36 PM	1.5	761 WASHINGTON AVE		Homeowner/ Resident	Dry	Grease	100 – 1,000	No	N/A	Regular maintenance of sewer	Regular maintenance of main sewer	Tom Hill Septic/Septage hauler	11/13/2014	
12/9/2014 11:40 AM	0.1	MH (10-147)	corner of York and Campbell	WPCC employee	Wet	Other (Blockage)	100 – 1,000	Yes	Cove River	Regular maintenance of sewer	Regular maintenance of main sewer	N/A	12/9/2014	
12/9/2014 2:30 PM	0.5	MH (7-51)	corner of Cold Spring Road and Hilltop Lane	Homeowner/ Resident	Wet	Other (Blockage)	100 – 1,000	Yes	Cove River	Regular maintenance of sewer	Regular maintenance of main sewer	N/A	12/9/2014	
12/9/2014 9:00 PM	0.25	MH (16-71)	near 197 Lee Street	Police Department	Dry	Unknown	1,000 – 25,000	Yes	Long Island Sound	Regular maintenance of sewer	Regular maintenance of main sewer	West Haven personnel cleaned area	12/9/2014	
12/18/2014 12:48 PM	0.25	15 OLIVER LA		Homeowner/ Resident	Dry	Grease	10 – 50	No	N/A	Regular maintenance of sewer	Regular maintenance of main sewer	Service Master/Other contractor	12/18/2014	
12/26/2014 9:05 AM	0.25	Main Pump Station	N/A	WPCC employee	Dry	Other (Blockage)	50 – 100	Yes	New Haven Harbor	Other: Cleared blockage and washed compactor	Other: Switch washer compactors and on alarm system is set to be installed and checked daily	West Haven personnel cleaned area	12/26/2014	3/16/2014
12/28/2014 3:15 PM	0.75	125 BLUFF AVE	N/A	WPCC employee	Dry	Other (Rags)	10 – 50	No	N/A	Regular maintenance of sewer	Regular maintenance of main sewer	West Haven personnel cleaned area	12/28/2014	
1/9/2015 9:15 AM	0.25	MH (2-215)	corner of South Street and Great Circle Road	WPCC employee	Dry	Grease	10 – 50	Yes	Long Island Sound	Regular maintenance of sewer	Regular maintenance of main sewer	N/A	1/9/2015	6/12/2009
1/20/2015 12:25 PM	0.75	57-59 ADMIRAL ST	N/A	Homeowner/ Resident	Dry	Grease	50 – 100	No	N/A	Regular maintenance of sewer	Regular maintenance of main sewer	Tom Hill Septic/Septage hauler	1/20/2015	10/28/2009
1/25/2015 1:55 PM	4	136 OCEAN AVE	N/A	Homeowner/ Resident	Dry	Grease	50 – 100	No	N/A	Regular maintenance of sewer	Regular maintenance of main sewer	Vactor truck	2/18/2015	

1. Volumes discharged are visual estimates. Ranges include the larger value in the range (ex: 10-50 gal includes 50 gal, where 50-100 gal includes 100 gal).
2. Where the bypass reached storm basins or surface waters, the volume discharged to the receiving water is assumed to be the entire volume reported.
3. Period of record: July 5, 2006 – December 31, 2017. Blank entry indicates that no previous bypass event occurred at this location during this period of record.

Appendix A: City of West Haven Collection System Releases From 1/1/2012 to 12/15/2017

Date/Time of Event	Duration (hours)	Bypass Location	More Description of Location	Source of Notification	Weather	Cause of Bypass	Volume ¹ (gallons)	Reached Catch Basin?	Affected Surface Water ²	Steps Taken to Stop Overflow	Steps Taken to Prevent Future Overflows	Cleaning Method	Date Reported to DEEP	Date of Last Bypass at this Location ³
3/5/2015 4:17 PM	0.1	MH (13-193)	Spring Street, by City dump	WPCC employee	Dry	Grease	10 – 50	No	N/A	Regular maintenance of sewer	Regular maintenance of main sewer	Vactor truck	3/6/2015	3/22/2013
3/27/2015 2:40 PM	0.5	Dawson Avenue Pump Station	N/A	Homeowner/ Resident	Dry	Electrical Equipment Failure	10 – 50	No	N/A	Other: pumps restarted immediately	Other: evaluating problem with electrical panel	N/A	3/27/2015	10/29/2012
4/12/2015 5:08 PM	0.5	MH (5-231)	Rock Street	Police Department	Dry	Grease	10 – 50	No	N/A	Regular maintenance of sewer	Regular maintenance of main sewer	Vactor truck	4/13/2015	
4/30/2015 3:45 PM	0.5	MH (6-107)	N/A	Homeowner/ Resident	Dry	Grease	50 – 100	No	N/A	Regular maintenance of sewer	Regular maintenance of main sewer	Vactor truck	4/30/2015	7/15/2013
5/1/2015 9:40 AM	1	MH (13-148)	corner of Boston Post Road and Wade Street	Homeowner/ Resident	Dry	Other (Rags)	50 – 100	Yes	Club Creek	Regular maintenance of sewer	Regular maintenance of main sewer	West Haven personnel cleaned area	5/5/2015	12/17/2009
5/1/2015 10:50 AM	1.75	MH (16-137)	corner of Boston Post Road and Brower Street	WPCC employee	Dry	Grease	50 – 100	Yes	Club Creek	Regular maintenance of sewer	Regular maintenance of main sewer	Tom Hill Septic/Septage hauler	5/1/2015	
5/1/2015 4:50 PM	2.75	MH (13-166)	N/A	Homeowner/ Resident	Dry	Grease	10 – 50	No	N/A	Regular maintenance of sewer	Regular maintenance of main sewer	Vactor truck	5/1/2015	10/26/2009
5/7/2015 9:55 AM	0.5	MH (13-145)	114 Boston Post Road	Homeowner/ Resident	Dry	Other (Rags)	10 – 50	Yes	West River	Regular maintenance of sewer	Regular maintenance of main sewer	Vactor truck	5/7/2015	
5/20/2015 4:45 PM	2	MH (4-95)	behind Ora Mason Library	Homeowner/ Resident	Dry	Grease	100 – 1,000	No	N/A	Regular maintenance of sewer	Regular maintenance of main sewer	Tom Hill Septic/Septage hauler	5/20/2015	
6/13/2015 8:15 AM	0.75	MH (10-309)	West Spring Street and Greta Street	Homeowner/ Resident	Dry	Grease	10 – 50	Yes	Cove River	Regular maintenance of sewer	Regular maintenance of main sewer	Vactor truck	6/13/2015	6/20/2013
6/19/2015 8:30 AM	0.75	MH (13-205)	corner of Spring Street and Front Avenue	Other (Person driving by)	Dry	Grease	10 – 50	Yes	Long Island Sound	Regular maintenance of sewer	Regular maintenance of main sewer	Vactor truck	6/19/2015	3/12/2008

1. Volumes discharged are visual estimates. Ranges include the larger value in the range (ex: 10-50 gal includes 50 gal, where 50-100 gal includes 100 gal).

2. Where the bypass reached storm basins or surface waters, the volume discharged to the receiving water is assumed to be the entire volume reported.

3. Period of record: July 5, 2006 – December 31, 2017. Blank entry indicates that no previous bypass event occurred at this location during this period of record.

Appendix A: City of West Haven Collection System Releases From 1/1/2012 to 12/15/2017

Date/Time of Event	Duration (hours)	Bypass Location	More Description of Location	Source of Notification	Weather	Cause of Bypass	Volume ¹ (gallons)	Reached Catch Basin?	Affected Surface Water ²	Steps Taken to Stop Overflow	Steps Taken to Prevent Future Overflows	Cleaning Method	Date Reported to DEEP	Date of Last Bypass at this Location ³
6/19/2015 11:50 AM	0.25	MH (10-147)	corner of York Street at Campbell Avenue	Other (Person driving by)	Dry	Grease	50 – 100	Yes	Long Island Sound	Regular maintenance of sewer	Regular maintenance of main sewer	Vactor truck	6/19/2015	
7/29/2015 8:15 PM	0.5	MH (12-147)	744 Boston Post Road	Homeowner/Resident	Dry	Grease	10 – 50	No	N/A	Regular maintenance of sewer	Regular maintenance of main sewer	Vactor truck	7/30/2015	
8/7/2015 7:18 AM	0.75	MH (2-181)	Near 16 Ida Lane	Homeowner/Resident	Dry	Grease	100 – 1,000	Yes	N/A	Regular maintenance of sewer	Regular maintenance of main sewer	Vactor truck	8/7/2015	8/29/2014
8/8/2015 1:45 PM	0.25	MH (7-39)	Near 3 Cold Spring Road	WPCC employee	Dry	Grease	10 – 50	No	N/A	Regular maintenance of sewer	Regular maintenance of main sewer	West Haven personnel cleaned area	8/8/2015	1/1/2007
9/4/2015 4:14 PM	1	MH (13-237)	Near 78 Dana Street	Homeowner/Resident	Dry	Grease	100 – 1,000	Yes	N/A	Regular maintenance of sewer	Regular maintenance of main sewer	Service Master/Other contractor	9/4/2015	
9/20/2015 3:30 PM	1	108 DAVID ST	N/A	Homeowner/Resident	Dry	Grease	100 – 1,000	Yes	N/A	Regular maintenance of sewer	Regular maintenance of main sewer	Service Master/Other contractor	9/20/2015	
9/21/2015 11:25 AM	0.5	MH (13-196)	Cul-de-sac at end of Lambert Street	WPCC employee	Dry	Grease	10 – 50	No	West River	Regular maintenance of sewer	Regular maintenance of main sewer	Vactor truck	9/21/2015	1/22/2008
9/23/2015 1:30 PM	0.5	MH (11-96)	Intersection of 3rd Ave and White Street	Homeowner/Resident	Dry	Mechanical Equipment Failure	10 – 50	No	N/A	Other: Construction company Komar to repair sewer line on 9-24-2015	Other: Construction company Komar to repair sewer line on 9-24-2015	Vactor truck	9/23/2015	
10/19/2015 3:30 PM	0.1	19 HARDING AVE	N/A	Homeowner/Resident	Dry	Grease	50 – 100	No	N/A	Regular maintenance of sewer	Regular maintenance of main sewer	Service Master/Other contractor	10/19/2015	5/19/2015
10/19/2015 3:40 PM	3.5	33 HARDING LN	N/A	Homeowner/Resident	Dry	Grease	10 – 50	No	N/A	Regular maintenance of sewer	Regular maintenance of main sewer	Vactor truck	10/19/2015	5/1/2014

1. Volumes discharged are visual estimates. Ranges include the larger value in the range (ex: 10-50 gal includes 50 gal, where 50-100 gal includes 100 gal).
2. Where the bypass reached storm basins or surface waters, the volume discharged to the receiving water is assumed to be the entire volume reported.
3. Period of record: July 5, 2006 – December 31, 2017. Blank entry indicates that no previous bypass event occurred at this location during this period of record.

Appendix A: City of West Haven Collection System Releases From 1/1/2012 to 12/15/2017

Date/Time of Event	Duration (hours)	Bypass Location	More Description of Location	Source of Notification	Weather	Cause of Bypass	Volume ¹ (gallons)	Reached Catch Basin?	Affected Surface Water ²	Steps Taken to Stop Overflow	Steps Taken to Prevent Future Overflows	Cleaning Method	Date Reported to DEEP	Date of Last Bypass at this Location ³
11/9/2015 10:00 AM	0.75	Baybrook Pump Station	1 Bayshore Drive	Plumber/ Contractor	Dry	Electrical Equipment Failure	50 – 100	No	N/A	Regular maintenance of sewer	Regular maintenance of main sewer	Vactor truck	11/9/2015	
11/13/2015 1:40 PM	0.1	MH (13-193)	Spring Street	WPCC employee	Dry	Grease	50 – 100	Yes	West River	Regular maintenance of sewer	Regular maintenance of main sewer	West Haven personnel cleaned area	11/13/2015	3/6/2015
11/27/2015 12:28 PM	0.5	MH (10-299, 10-299A, 10-299B)	Sawmill Road	Police Department	Dry	Grease	50 – 100	No	N/A	Regular maintenance of sewer	Regular maintenance of main sewer	West Haven personnel cleaned area	11/27/2015	
11/30/2015 12:00 PM	0.1	128 CENTER ST	N/A	Homeowner/ Resident	Dry	Grease	50 – 100	No	N/A	Regular maintenance of sewer	Regular maintenance of main sewer	Tom Hill Septic/Septage hauler	11/30/2015	
11/30/2015 2:06 PM	0.75	MH (10-335)	40 Coleman Street	WPCC employee	Dry	Grease	1,000 – 25,000	Yes	Cove River	Regular maintenance of sewer	Regular maintenance of main sewer	Service Master/Other contractor	12/1/2015	
12/14/2015 9:45 AM	0.5	21 OCALA ST	N/A	Homeowner/ Resident	Dry	Grease	50 – 100	No	N/A	N/A		Tom Hill Septic/Septage hauler	12/14/2015	
12/18/2015 8:15 AM	0.75	MH (13-102)	18 Tile Street	Homeowner/ Resident	Dry	Grease	10 – 50	No	Cove River	Regular maintenance of sewer	Regular maintenance of main sewer	Vactor truck	12/18/2015	
12/21/2015 8:40 AM	0.25	21 OCALA ST	N/A	Homeowner/ Resident	Dry	Grease	10 – 50	No	N/A	Regular maintenance of sewer	Regular maintenance of main sewer	Service Master/Other contractor	12/21/2015	12/14/2015
12/24/2015 9:50 AM	0.5	463 CAMPBELL AVE	N/A	Homeowner/ Resident	Dry	Grease	50 – 100	No	N/A	Regular maintenance of sewer	Regular maintenance of main sewer	Homeowner cleaned the area	12/24/2015	1/30/2011
12/27/2015 10:15 PM	1	MH (7-112)	30 Cove Brook Road	Homeowner/ Resident	Dry	Other (Rags)	100 – 1,000	Yes	Cove River	Regular maintenance of sewer	Regular maintenance of main sewer	West Haven personnel cleaned area	12/28/2015	
1/9/2016 12:40 PM	2	457 OCEAN AVE	N/A	Homeowner/ Resident	Dry	Grease	10 – 50	No	N/A	Regular maintenance of sewer	Regular maintenance of main sewer	West Haven personnel cleaned area	1/9/2016	3/15/2010

1. Volumes discharged are visual estimates. Ranges include the larger value in the range (ex: 10-50 gal includes 50 gal, where 50-100 gal includes 100 gal).
2. Where the bypass reached storm basins or surface waters, the volume discharged to the receiving water is assumed to be the entire volume reported.
3. Period of record: July 5, 2006 – December 31, 2017. Blank entry indicates that no previous bypass event occurred at this location during this period of record.

Appendix A: City of West Haven Collection System Releases From 1/1/2012 to 12/15/2017

Date/Time of Event	Duration (hours)	Bypass Location	More Description of Location	Source of Notification	Weather	Cause of Bypass	Volume ¹ (gallons)	Reached Catch Basin?	Affected Surface Water ²	Steps Taken to Stop Overflow	Steps Taken to Prevent Future Overflows	Cleaning Method	Date Reported to DEEP	Date of Last Bypass at this Location ³
1/25/2016 8:38 PM	0.75	229 TERRACE AVE	N/A	Homeowner/Resident	Dry	Grease	50 – 100	No	N/A	Regular maintenance of sewer	Regular maintenance of main sewer	Service Master/Other contractor	1/25/2016	
1/26/2016 8:10 AM	0.1	MH (2-53)	near 17 Batt Lane	Homeowner/Resident	Dry	Grease	100 – 1,000	Yes	N/A	Regular maintenance of sewer	Regular maintenance of main sewer	Vactor truck	1/26/2016	8/8/2010
2/1/2016 10:15 AM	0.75	MH (13-165)	near 59 Locust St	Homeowner/Resident	Dry	Grease	50 – 100	No	N/A	Regular maintenance of sewer	Regular maintenance of main sewer	West Haven personnel cleaned area	2/1/2016	
2/1/2016 12:15 PM	0.1	MH (12-3)	near 175 Canton St	Homeowner/Resident	Dry	Grease	50 – 100	No	N/A	Regular maintenance of sewer	Regular maintenance of main sewer	West Haven personnel cleaned area	2/1/2016	
2/12/2016 8:40 AM	0.1	MH (5-133)	near 119 Bluff Ave	WPCC employee	Dry	Other (Rags)	10 – 50	No	N/A	Regular maintenance of sewer	Regular maintenance of main sewer	West Haven personnel cleaned area	2/12/2016	4/17/2011
2/14/2016 12:20 PM	0.75	MH (8-24)	near 100 Campbell Ave	Homeowner/Resident	Dry	Grease	10 – 50	No	N/A	Regular maintenance of sewer	Regular maintenance of main sewer	West Haven personnel cleaned area	2/14/2016	3/5/2013
3/3/2016 8:05 AM	1.25	MH (5-135)	near 124 Bluff Ave	Homeowner/Resident	Dry	Grease	100 – 1,000	Yes	Long Island Sound	Regular maintenance of sewer	Regular maintenance of main sewer	West Haven personnel cleaned area	3/3/2016	
3/5/2016 10:30 AM	1.25	MH (5-135)	near 124 Bluff Ave	WPCC employee	Dry	Other (Grease, roots, and rags)	100 – 1,000	Yes	Long Island Sound	Regular maintenance of sewer	Regular maintenance of main sewer	West Haven personnel cleaned area	3/5/2016	3/3/2016
3/10/2016 9:12 AM	0.25	MH (13-165)	near 59 Locust St	Homeowner/Resident	Dry	Grease	10 – 50	No	N/A	Regular maintenance of sewer	Regular maintenance of main sewer	Vactor truck	3/10/2016	2/1/2016
3/13/2016 1:40 PM	0.75	92 PUTNEY DR	N/A	Homeowner/Resident	Dry	Other (Rags)	10 – 50	No	N/A	Regular maintenance of sewer	Regular maintenance of main sewer	Service Master/Other contractor	3/13/2016	
3/16/2016 9:36 AM	0.25	MH (16-164)	Orange Ave - end of Gilbert St	WPCC employee	Dry	Other (Rags)	50 – 100	No	N/A	Regular maintenance of sewer	Regular maintenance of main sewer	West Haven personnel cleaned area	3/16/2016	4/8/2011

1. Volumes discharged are visual estimates. Ranges include the larger value in the range (ex: 10-50 gal includes 50 gal, where 50-100 gal includes 100 gal).
2. Where the bypass reached storm basins or surface waters, the volume discharged to the receiving water is assumed to be the entire volume reported.
3. Period of record: July 5, 2006 – December 31, 2017. Blank entry indicates that no previous bypass event occurred at this location during this period of record.

Appendix A: City of West Haven Collection System Releases From 1/1/2012 to 12/15/2017

Date/Time of Event	Duration (hours)	Bypass Location	More Description of Location	Source of Notification	Weather	Cause of Bypass	Volume ¹ (gallons)	Reached Catch Basin?	Affected Surface Water ²	Steps Taken to Stop Overflow	Steps Taken to Prevent Future Overflows	Cleaning Method	Date Reported to DEEP	Date of Last Bypass at this Location ³
3/21/2016 2:35 PM	2.25	MH (3-70)	Near 12 Arlington St	WPCC employee	Dry	Grease	100 – 1,000	Yes	Long Island Sound	Regular maintenance of sewer	Regular maintenance of main sewer	Vactor truck	3/21/2016	
3/31/2016 7:05 PM	1.5	Woodycrest Pump Station	457 Ocean Ave	Homeowner/ Resident	Dry	Mechanical Equipment Failure	100 – 1,000	No	N/A	Regular maintenance of sewer	Regular maintenance of main sewer	Service Master/Other contractor	3/31/2016	
4/16/2016 11:30 AM	0.25	MH (16-137)	Intersection of Brower St and Boston Post Rd	Police Department	Dry	Other (Rags)	100 – 1,000	Yes	Club Creek	Regular maintenance of sewer	Regular maintenance of main sewer	Vactor truck	4/16/2016	5/1/2015
4/29/2016 5:34 PM	3	Main Sewer	near 52 Peabody St	Homeowner/ Resident	Dry	Other (Grease and Rags)	100 – 1,000	Yes	Cove River	Regular maintenance of sewer	Regular maintenance of main sewer	Vactor truck	4/29/2016	
5/4/2016 10:00 AM	0.5	MH (10-16)	near 30 Voss Rd	WPCC employee	Dry	Other (Grease and Roots)	100 – 1,000	Yes	Cove River	Regular maintenance of sewer	Regular maintenance of main sewer	Vactor truck	5/4/2016	
5/15/2016 2:48 PM	1	MH (10-143)	near 90 Clark Street	Homeowner/ Resident	Dry	Other (Rags)	50 – 100	Yes	Cove River	Regular maintenance of sewer	Regular maintenance of main sewer	West Haven personnel cleaned area	5/15/2016	
5/21/2016 6:40 PM	0.1	34 HOMESTEAD AVE	N/A	Homeowner/ Resident	Dry	Other (Grease and Rags)	10 – 50	No	N/A	Regular maintenance of sewer	Regular maintenance of main sewer	Service Master/Other contractor	5/21/2016	5/1/2015
5/23/2016 3:00 PM	0.1	MH (13-250)	Campbell Ave and 1st Ave Intersection	WPCC employee	Dry	Other (Roots and Rags)	10 – 50	Yes	N/A	Regular maintenance of sewer	Regular maintenance of main sewer	Vactor truck	5/23/2016	2/23/2009
6/17/2016 11:20 AM	5	Other:	Orange Ave (Under bridge)	Plumber/ Contractor	Dry	Unknown	10 – 50	No	West River	Regular maintenance of sewer	Regular maintenance of main sewer	Vactor truck	6/17/2016	1/10/2016
6/18/2016 5:15 PM		Other:	Orange Ave (Under bridge)	WPCC employee	Dry	Unknown	Unknown	No	West River	Other: Dig up and repair pipe	Regular maintenance of main sewer	Vactor truck	6/18/2016	
6/30/2016 10:30 PM	0.5	MH (7-190)	near 412 Kelsey Avenue	Homeowner/ Resident	Dry	Other (Grease and Rags)	50 – 100	No	N/A	Regular maintenance of sewer	Regular maintenance of main sewer	West Haven personnel cleaned area	6/30/2016	

1. Volumes discharged are visual estimates. Ranges include the larger value in the range (ex: 10-50 gal includes 50 gal, where 50-100 gal includes 100 gal).
2. Where the bypass reached storm basins or surface waters, the volume discharged to the receiving water is assumed to be the entire volume reported.
3. Period of record: July 5, 2006 – December 31, 2017. Blank entry indicates that no previous bypass event occurred at this location during this period of record.

Appendix A: City of West Haven Collection System Releases From 1/1/2012 to 12/15/2017

Date/Time of Event	Duration (hours)	Bypass Location	More Description of Location	Source of Notification	Weather	Cause of Bypass	Volume ¹ (gallons)	Reached Catch Basin?	Affected Surface Water ²	Steps Taken to Stop Overflow	Steps Taken to Prevent Future Overflows	Cleaning Method	Date Reported to DEEP	Date of Last Bypass at this Location ³
7/1/2016 11:27 AM	0.1	9 WARD PL	N/A	Homeowner/ Resident	Dry	Other (Grease and Rags)	50 – 100	No	N/A	Regular maintenance of sewer	Regular maintenance of main sewer	West Haven personnel cleaned area	7/1/2016	
7/8/2016 6:25 PM	1.5	219 COLONIAL BLVD	N/A	Homeowner/ Resident	Dry	Other (Grease and Rags)	50 – 100	No	N/A	Regular maintenance of sewer	Regular maintenance of main sewer	Tom Hill Septic/Septage hauler	7/8/2016	
7/9/2016 11:35 PM	0.25	19 HARDING AVE	N/A	Homeowner/ Resident	Dry	Other (Grease and Rags)	50 – 100	No	N/A	Regular maintenance of sewer	Regular maintenance of main sewer	West Haven personnel cleaned area	7/10/2016	10/19/2015
7/19/2016 9:40 PM	1	MH (12-147)	near 744 West Post Road	Police Department	Dry	Grease	10 – 50	No	N/A	Regular maintenance of sewer	Regular maintenance of main sewer	Vactor truck	7/19/2016	7/29/2015
8/14/2016 10:30 AM	0.25	59 LOCUST ST	N/A	Homeowner/ Resident	Dry	Grease	< 10	No	N/A	Regular maintenance of sewer	Regular maintenance of main sewer	West Haven personnel cleaned area	8/14/2016	7/6/2010
9/12/2016 8:48 AM	0.5	MH (16-135)	near 10 Forest Road	Other (construction worker at site)	Dry	Other (Rags)	50 – 100	No	N/A	Regular maintenance of sewer	Regular maintenance of main sewer	Vactor truck	9/12/2016	
9/13/2016 9:00 AM	0.5	MH (16-71)	N/A	Homeowner/ Resident	Dry	Grease	50 – 100	No	N/A	Regular maintenance of sewer	Regular maintenance of main sewer	West Haven personnel cleaned area	9/13/2016	12/9/2014
9/20/2016 7:50 AM	0.5	MH (12-6)	near 440 Meloy Road	Homeowner/ Resident	Dry	Grease	100 – 1,000	No	N/A	Regular maintenance of sewer	Regular maintenance of main sewer	Vactor truck	9/20/2016	1/24/2009
10/12/2016 8:15 AM	0.5	MH (10-310)	317 West Spring Street	Homeowner/ Resident	Dry	Grease	50 – 100	No	N/A	Regular maintenance of sewer	Regular maintenance of main sewer	Vactor truck	10/12/2016	12/20/2013
10/16/2016 8:01 PM	1	89 HOMESIDE AVE	N/A	Homeowner/ Resident	Dry	Grease	< 10	No	N/A	Regular maintenance of sewer	Regular maintenance of main sewer	Homeowner cleaned the area	10/16/2016	
10/28/2016 9:10 AM	0.5	MH (7-112)	36 Cove Brook Road	Homeowner/ Resident	Dry	Roots	50 – 100	Yes	Cove River	Regular maintenance of sewer	Regular maintenance of main sewer	West Haven personnel cleaned area	10/28/2016	12/27/2015

1. Volumes discharged are visual estimates. Ranges include the larger value in the range (ex: 10-50 gal includes 50 gal, where 50-100 gal includes 100 gal).

2. Where the bypass reached storm basins or surface waters, the volume discharged to the receiving water is assumed to be the entire volume reported.

3. Period of record: July 5, 2006 – December 31, 2017. Blank entry indicates that no previous bypass event occurred at this location during this period of record.

Appendix A: City of West Haven Collection System Releases From 1/1/2012 to 12/15/2017

Date/Time of Event	Duration (hours)	Bypass Location	More Description of Location	Source of Notification	Weather	Cause of Bypass	Volume ¹ (gallons)	Reached Catch Basin?	Affected Surface Water ²	Steps Taken to Stop Overflow	Steps Taken to Prevent Future Overflows	Cleaning Method	Date Reported to DEEP	Date of Last Bypass at this Location ³
11/23/2016 11:30 AM	3	142 KELSEY AVE	140 and 142 Kelsey Ave	Homeowner/Resident	Dry	Other (Grease and Rags)	10 – 50	No	N/A	Regular maintenance of sewer	Regular maintenance of main sewer	Service Master/Other contractor	11/23/2016	
12/4/2016 10:15 PM	2	99 COLEMAN ST	N/A	Homeowner/Resident	Dry	Grease	10 – 50	No	N/A	Regular maintenance of sewer	Regular maintenance of main sewer	West Haven personnel cleaned area	12/5/2016	
12/31/2016 12:25 PM	0.75	MH (10-267)	32 York St	Police Department	Dry	Debris	50 – 100	Yes	Cove River	Regular maintenance of sewer	Regular maintenance of main sewer	West Haven personnel cleaned area	12/31/2016	6/15/2015
1/11/2017 11:30 AM	0.75	100 CAMPBELL AVE	N/A	Homeowner/Resident	Wet	Grease	1,000 – 25,000	No	N/A	Regular maintenance of sewer	Regular maintenance of main sewer	Service Master/Other contractor	1/11/2017	2/16/2016
1/16/2017 7:20 PM	1	MH (10-316)	near 5 - 6 Greta Street	Homeowner/Resident	Dry	Grease	10 – 50	No	N/A	Regular maintenance of sewer	Regular maintenance of main sewer	N/A	1/16/2017	
1/18/2017 8:33 AM	0.5	MH (2-376A)	near 475 Ocean Ave	Homeowner/Resident	Wet	Grease	50 – 100	No	N/A	Regular maintenance of sewer	Regular maintenance of main sewer	N/A	1/18/2017	3/31/2016
1/20/2017 10:35 AM	0.25	89 BEATRICE DR	N/A	Homeowner/Resident	Dry	Grease	10 – 50	No	N/A	Regular maintenance of sewer	Regular maintenance of main sewer	Service Master/Other contractor	1/20/2017	6/2/2010
1/20/2017 8:34 PM	1	MH (8-95)	near 2 Williams Street	Police Department	Dry	Open Hydrant	100 – 1,000	Yes	Old Field Creek	Regular maintenance of sewer	Regular maintenance of main sewer	N/A	1/20/2017	
2/7/2017 7:00 AM	0.25	MH (2-171)	near 181 Beatrice Drive	Homeowner/Resident	Dry	Other (Rags)	50 – 100	No	N/A	Regular maintenance of sewer	Regular maintenance of main sewer	N/A	2/7/2017	5/1/2014
2/14/2017 11:05 AM	0.5	MH (2-334C)	N/A	Plumber/Contractor	Dry	Other (Rags)	10 – 50	No	N/A	Regular maintenance of sewer	Regular maintenance of main sewer	N/A	2/14/2017	

1. Volumes discharged are visual estimates. Ranges include the larger value in the range (ex: 10-50 gal includes 50 gal, where 50-100 gal includes 100 gal).

2. Where the bypass reached storm basins or surface waters, the volume discharged to the receiving water is assumed to be the entire volume reported.

3. Period of record: July 5, 2006 – December 31, 2017. Blank entry indicates that no previous bypass event occurred at this location during this period of record.

Appendix A: City of West Haven Collection System Releases From 1/1/2012 to 12/15/2017

Date/Time of Event	Duration (hours)	Bypass Location	More Description of Location	Source of Notification	Weather	Cause of Bypass	Volume ¹ (gallons)	Reached Catch Basin?	Affected Surface Water ²	Steps Taken to Stop Overflow	Steps Taken to Prevent Future Overflows	Cleaning Method	Date Reported to DEEP	Date of Last Bypass at this Location ³
2/23/2017 5:00 PM	11	MH (4-6)	near 300 Callegari Drive (cross country in back of lot)	Police Department	Dry	Vandalism	> 100,000	Yes	Oyster River	Other:	Cleaned out sewer line and replaced cover	N/A	2/24/2017	
3/7/2017 12:30 PM	0.5	Mobile Bypass Pumping Unit	Cove River Pump Station Kelsey Avenue	WPCC employee	Dry	Mechanical Equipment Failure	50 – 100	Yes	Cove River	Other:	Issue with piping and pump	Vactor truck	3/7/2017	1/9/2014
3/9/2017 6:47 PM	2.5	63 RUBY RD	N/A	Homeowner/Resident	Dry	Grease	10 – 50	No	N/A	Regular maintenance of sewer	Regular maintenance of main sewer	Service Master/Other contractor	3/9/2017	4/21/2009
3/20/2017 4:10 PM	3	MH (5-231A)	Rock St near Jimmies	Homeowner/Resident	Dry	Grease	10 – 50	No	N/A	Regular maintenance of sewer	Regular maintenance of main sewer	N/A	3/20/2017	4/12/2015
4/4/2017 7:12 AM	7	Dawson Avenue Pump Station	Manhole 3-19 outside of pump station overflowed as well	WPCC employee	Wet	Heavy Rain	100 – 1,000	No	N/A	Regular maintenance of sewer	Regular maintenance of main sewer	N/A	4/4/2017	3/27/2015
4/4/2017 7:30 AM	6.5	MH (5-85)	Usher Ct	WPCC employee	Wet	Heavy Rain	100 – 1,000	Yes	Long Island Sound	Regular maintenance of sewer	Regular maintenance of main sewer	N/A	4/4/2017	
4/4/2017 7:30 AM	6.5	MH (5-39)	Ocean Ave and Grove Place	WPCC employee	Wet	Heavy Rain	100 – 1,000	Yes	Long Island Sound	Regular maintenance of sewer	Regular maintenance of main sewer	N/A	4/4/2017	4/23/2011
4/4/2017 8:30 AM	5.5	MH (7-137)	near 467 Painter Dr	WPCC employee	Wet	Heavy Rain	100 – 1,000	Yes	Cove River	Regular maintenance of sewer	Regular maintenance of main sewer	N/A	4/4/2017	12/13/2010
4/6/2017 7:19 PM	2.5	118 PEABODY ST	N/A	Homeowner/Resident	Wet	Grease	10 – 50	No	N/A	Regular maintenance of sewer	Regular maintenance of main sewer	Service Master/Other contractor	4/6/2017	
4/6/2017 8:20 PM	1.5	MH (5-39)	Ocean Ave at Grove Pl	WPCC employee	Wet	Heavy Rain	100 – 1,000	Yes	Long Island Sound	Regular maintenance of sewer	Regular maintenance of main sewer	N/A	4/6/2017	4/4/2017

1. Volumes discharged are visual estimates. Ranges include the larger value in the range (ex: 10-50 gal includes 50 gal, where 50-100 gal includes 100 gal).

2. Where the bypass reached storm basins or surface waters, the volume discharged to the receiving water is assumed to be the entire volume reported.

3. Period of record: July 5, 2006 – December 31, 2017. Blank entry indicates that no previous bypass event occurred at this location during this period of record.

Appendix A: City of West Haven Collection System Releases From 1/1/2012 to 12/15/2017

Date/Time of Event	Duration (hours)	Bypass Location	More Description of Location	Source of Notification	Weather	Cause of Bypass	Volume ¹ (gallons)	Reached Catch Basin?	Affected Surface Water ²	Steps Taken to Stop Overflow	Steps Taken to Prevent Future Overflows	Cleaning Method	Date Reported to DEEP	Date of Last Bypass at this Location ³
4/6/2017 8:20 PM	2	MH (5-85)	near 6 Usher Ct	WPCC employee	Wet	Heavy Rain	100 – 1,000	Yes	Long Island Sound	Regular maintenance of sewer	Regular maintenance of main sewer	N/A	4/6/2017	4/4/2017
4/8/2017 8:53 AM	0.5	MH (2-181)	near 16 Ida Lane	Homeowner/Resident	Dry	Grease	100 – 1,000	Yes	Oyster River	Regular maintenance of sewer	Regular maintenance of main sewer	N/A	4/10/2017	8/7/2015
4/22/2017 9:10 PM	1	42 FOREST RD	N/A	Homeowner/Resident	Dry	Grease	100 – 1,000	No	N/A	Regular maintenance of sewer	Regular maintenance of main sewer	Service Master/Other contractor	4/22/2017	2/2/2010
4/24/2017 11:00 AM	0.5	MH (11-14)	near 119 Brown Street	Homeowner/Resident	Dry	Grease	10 – 50	No	N/A	Regular maintenance of sewer	Regular maintenance of main sewer	N/A	4/24/2017	
4/27/2017 9:30 AM	0.15	MH (12-115)	behind 52 Peabody St	Homeowner/Resident	Dry	Other (Sewer Line Blockage)	10 – 50	Yes	Cove River	Regular maintenance of sewer	Regular maintenance of main sewer	N/A	4/27/2017	4/29/2016
4/27/2017 2:40 PM	0.5	Dawson Avenue Pump Station	MHs 3-19, 3-73, 3-72 in front of PS surcharged	Police Department	Dry	Mechanical Equipment Failure	10 – 50	No	N/A	Regular maintenance of sewer	Regular maintenance of main sewer	N/A	4/27/2017	4/4/2017
5/3/2017 11:50 AM	0.5	MH (9-84)	near 32 Eileen Road	Homeowner/Resident	Dry	Grease	10 – 50	Yes	Cove River	Regular maintenance of sewer	Regular maintenance of main sewer	N/A	5/3/2017	11/2/2013
5/5/2017 3:45 PM	1.75	33 HARDING AVE	N/A	Homeowner/Resident	Wet	Grease	50 – 100	No	N/A	Regular maintenance of sewer	Regular maintenance of main sewer	Service Master/Other contractor	5/5/2017	7/9/2016
5/17/2017 11:51 AM	1	33 SYCAWAY ST	N/A	Plumber/Contractor	Dry	Grease	10 – 50	No	N/A	Regular maintenance of sewer	Regular maintenance of main sewer	Service Master/Other contractor	5/17/2017	
6/10/2017 9:51 AM	1	Main Sewer	8-183:8-182, Morse Ave	Homeowner/Resident	Dry	Grease	10 – 50	Yes	Long Island Sound	Regular maintenance of sewer	Regular maintenance of main sewer	N/A	6/10/2017	2/25/2014
6/10/2017 11:20 AM	0.25	120 BROWN ST	N/A	Homeowner/Resident	Dry	Grease	10 – 50	No	N/A	Regular maintenance of sewer	Regular maintenance of main sewer	Service Master/Other contractor	6/10/2017	4/24/2017

1. Volumes discharged are visual estimates. Ranges include the larger value in the range (ex: 10-50 gal includes 50 gal, where 50-100 gal includes 100 gal).

2. Where the bypass reached storm basins or surface waters, the volume discharged to the receiving water is assumed to be the entire volume reported.

3. Period of record: July 5, 2006 – December 31, 2017. Blank entry indicates that no previous bypass event occurred at this location during this period of record.

Appendix A: City of West Haven Collection System Releases From 1/1/2012 to 12/15/2017

Date/Time of Event	Duration (hours)	Bypass Location	More Description of Location	Source of Notification	Weather	Cause of Bypass	Volume ¹ (gallons)	Reached Catch Basin?	Affected Surface Water ²	Steps Taken to Stop Overflow	Steps Taken to Prevent Future Overflows	Cleaning Method	Date Reported to DEEP	Date of Last Bypass at this Location ³
6/23/2017 6:15 AM	0.25	Morrissey Lane Pump Station	44 Morrissey Lane	Homeowner/Resident	Dry	Mechanical Equipment Failure	10 – 50	Yes	Oyster River	Regular maintenance of sewer	Regular maintenance of main sewer	N/A	6/23/2017	6/26/2015
7/5/2017 10:10 PM	0.25	49 PECK AVE	N/A	Police Department	Dry	Grease	10 – 50	No	N/A	Regular maintenance of sewer	Regular maintenance of main sewer	Service Master/Other contractor	7/5/2017	
7/9/2017 10:05 AM	0.5	MH (12-3)	near 146 Canton St	Homeowner/Resident	Dry	Grease	50 – 100	Yes	Cove River	Regular maintenance of sewer	Regular maintenance of main sewer	N/A	7/9/2017	2/1/2016
7/15/2017 12:45 PM	3	MH (12-3)	near 146 Canton St	Homeowner/Resident	Dry	Grease	50 – 100	Yes	Cove River	Regular maintenance of sewer	Regular maintenance of main sewer	N/A	7/15/2017	7/9/2017
8/22/2017 4:30 PM	0.25	457 OCEAN AVE	N/A	Homeowner/Resident	Dry	Mechanical Equipment Failure	10 – 50	No	N/A	Regular maintenance of sewer	Regular maintenance of main sewer	Service Master/Other contractor	8/22/2017	3/31/2016
8/30/2017 6:50 AM	0.5	MH (10-147)	near 706 Campbell Ave	WPCC employee	Dry	Grease	50 – 100	Yes	Cove River	Regular maintenance of sewer	Regular maintenance of main sewer	N/A	8/30/2017	6/19/2015
8/30/2017 8:20 AM	0.5	MH (13-194)	near 30 Lambert	Other (resident smelled odor)	Dry	Grease	50 – 100	Yes	Club Creek	Regular maintenance of sewer	Regular maintenance of main sewer	N/A	8/30/2017	9/21/2015
8/31/2017 8:11 AM	0.25	MH (2-181)	near 16 Ida Lane	Homeowner/Resident	Dry	Grease	100 – 1,000	Yes	Oyster River	Regular maintenance of sewer	Regular maintenance of main sewer	West Haven personnel cleaned area	8/31/2017	4/2/2017
9/24/2017 1:05 PM	0.5	MH (8-138)	near 269 Captain Thomas Blvd	Homeowner/Resident	Dry	Grease	10 – 50	Yes	Long Island Sound	Regular maintenance of sewer	Regular maintenance of main sewer	N/A	9/24/2017	
10/10/2017 10:00 AM	0.5	MH (12-8)	near 2 Knox St	Homeowner/Resident	Dry	Grease	100 – 1,000	No	N/A	Regular maintenance of sewer	Regular maintenance of main sewer	Vactor truck	10/10/2017	3/14/2014
11/27/2017 8:30 AM	1.5	1 FOREST RD	N/A	Homeowner/Resident	Dry	Grease	1,000 – 25,000	No	N/A	Regular maintenance of sewer	Regular maintenance of main sewer	Service Master, Tom Hill	12/30/2017	2/2/2010

1. Volumes discharged are visual estimates. Ranges include the larger value in the range (ex: 10-50 gal includes 50 gal, where 50-100 gal includes 100 gal).

2. Where the bypass reached storm basins or surface waters, the volume discharged to the receiving water is assumed to be the entire volume reported.

3. Period of record: July 5, 2006 – December 31, 2017. Blank entry indicates that no previous bypass event occurred at this location during this period of record.